

Test laboratory for the fire behavior of building materials, Dipl.-Ing. (FH) Andreas Hoch  
Testing, supervising and certifying body, authorized by the building supervision authority

# TEST REPORT

## PZ-Hoch-221030

**for the proof of Fire behaviour according to DIN 4102, part 1**

**Translation of the German test report – no guarantee for translation of technical terms**

<b>company</b>	<b>HUNTER DOUGLAS EUROPE BV</b> Piekstraat 2 NL - 3071 EL Rotterdam
<b>description of samples</b>	sunscreen fabric (comb-form) consisting of polyester in 2 different widths and in 3 different colours
<b>name of the material</b>	„Duette® Room Darkening FR“
<b>sampling</b>	by the company itself
<b>content of request</b>	Proof of flammability to classify building materials to class B1 “schwerentflammbar” according to DIN 4102, part 1
<b>validity of test report</b>	31.10.2027
<b>result</b>	<b>The examined product meets</b> <ul style="list-style-type: none"><li>• in any colour</li><li>• in folded width of <math>\approx 25\text{mm}</math> until <math>\approx 64\text{mm}</math></li><li>• with combs in <math>\approx 18\text{mm}</math> width x <math>\approx 8\text{mm}</math> height until <math>\approx 40\text{mm}</math> width x <math>\approx 23\text{mm}</math> height</li></ul> <b>the requirements of class B1 for “schwerentflammbare” (hardly flammable) building materials according to DIN 4102, part 1 (May 1998) , suspended freely or with distance of <math>&gt;40\text{ mm}</math> to same or other plain materials.</b>

This test report includes 8 pages and 11 enclosures.

Remark: If the above mentioned building material is not used as product according to MBO § 2, Abs. 9, Ziffer1, there is no need for a general building supervisory test report.

This test report is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17, Abs. 3).

This test report does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

- “allgemeine bauaufsichtliche Zulassung” (general building inspectorate approval ) or by
- „allgemeines bauaufsichtliches Prüfzeugnis“ (general building inspectorate certificate) or by
- “Zustimmung im Einzelfall” (exceptional approval)

This test report can underlie building supervisory procedures

- for regular building products for the prescribed proofs of conformity
- for non-regular building products for the needed proofs of applicability.

This test report must not be published and copied without preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents.